



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

MAY 24 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 6-7-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

WALK-IN

Address Being Appealed:

Number & Street: 1751 York City: St. Paul State: MN Zip: 55

Appellant/Applicant: Jen Stachowiac Email Stack05@live.com

Phone Numbers: Business (651) 367-4226 Residence _____ Cell _____

Signature: Jen Stachowiac Date: 5/24/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other _____
- Other _____
- Other _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: May 24, 2011

APPEAL PROPERTY ADDRESS: 1751 YORK AVE

APPLICANT NAME: GRANT REMODELING INC

PHONE NUMBER: 651-486-7500

PERMIT NUMBER: 11 105799

TYPE OF WINDOW Double hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	6.33	Difference from Required Area	+1.33
Width of Opening Minimum 20 Inches	24	Difference from Required Opening	+4
Height of Opening Minimum 24 Inches	19	Difference from Required Opening	-5
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	ok

COMMENTS: With the information provided, approval is recommended. 5-23-11 rr

Reviewed by: Rehn per Seeger's measurements.