



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 1, 2010

Jeff Beissel
Beissel Window and Siding, Co.
1635 Oakdale Ave
West St. Paul, MN 55118

VIA EMAIL: jeff@beisselwindows.com

Re: Appeal for property at 433 Wheelock Parkway West.
File ID: ALH 10-302

Dear Mr. Beissel:

This is to confirm that on October 28, 2010, Marcia Moermond, Legislative Hearing Officer reviewed your appeal in the above-referenced matter and recommended granting a 2.75-inch variance on the openable height of one double hung replacement egress bedroom window measuring 21.25 inches high by 27 inches wide.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Paralegal

cc: Fire Supervisors (email)
Pat Fish (email)
Jim Boom (email)
Ryan Rehn (email)
Stephen Ubl (email)

