



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

April 25, 2012

Chris McGrath
Harmony Homes, Inc.
o/b/o Phillip Stoyke
1120 Winter St
Minneapolis MN 55413

VIA EMAIL: cmcgrath@harmonyhomesinc.net

Re: Appeal for property at 1853 Highland Parkway

Dear Mr. McGrath:

This is to confirm that Marcia Moermond, Legislative Hearing Officer, has reviewed the above-referenced matter and recommended that the City Council grant a 2-inch variance on the openable height of three pocket/insert replacement egress windows measuring 22 inches high by 27 inches wide and grant a 6-inch variance on the openable height of one pocket/insert replacement egress window measuring 18 inches high by 23 inches wide.

The City Council Public Hearing is scheduled for Wednesday, May 16, 2012 at 5:30 p.m. in Room 300 Council Chambers; however, you don't need to attend since the appeal has been granted.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

MV

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Jim Bloom (email)
Stephen Ubl (email)
James Hoffman (email)