

RECEIVED

NOV 04 2010

CITY CLERK

**PLS Enterprises LLC
8715 Jewel Ave So.
Cottage Grove, Mn 55016
(651) 343-5805**

11/02/10

Dear Sir or Madam,

I am appealing the following line items on the attached "Fire Inspection Correction Notice"

Deficiency List

Item # 2 Egress Window in Attic Bedroom

The Egress window has been ordered and a permit will be pulled with the City Inspectors office in the near future. The Egress is a "special order" window that will not be available for installation fro an add'l 5-6 weeks.

I am requesting that the re-inspection of this deficiency be schedule for Mid-December to allow time for receipt of window and installation.

Item # 3 Northeast and Southeast Bedroom Windows

The windows in these bedrooms open up to a height of 21 inches versus the code requirement of 24 inches. These windows are approximately seven years old. They were professional installed by a Twin Cities window company. Due to the age of the replacement windows, I am requesting that these bedroom windows be allowed an exception to the code.

Item # 6 & 8 Exterior Surfaces

The paint surface on the Garage and Exterior window frames on the Porch are in need of some touch-up paint. Due to the season of cooler and cold weather, I am requesting that this deficiency be re-inspected in the Spring of 2011 in order to properly repair and re-apply a new coat of paint in said areas.

Thank you for considering my appeals,



**Patrick Siedow
PLS Enterprises LLC**