



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

March 11, 2011

Queschen Moet  
1081 Hague Ave  
St. Paul, MN 55104

Re: Appeal for property at 969 Marshall Avenue  
File ID: ALH 11-337

Dear Mr. Moet:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 7-inch variance on the openable height of the egress bedroom window on the 3<sup>rd</sup> floor. She recommended granting a 5-inch variance on the openable width of one casement replacement egress bedroom window measuring 43 inches high by 15 inches wide.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang  
Legislative Hearing Coordinator

c: Fire Supervisors (email)  
Jim Bloom (email)  
Stephen Ubl (email)  
Greg Johnson (email)  
File

