



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

March 17, 2011

David Stieber
8108 W. 96th Street
Bloomington MN 55438

Re: Appeal for property at 1210 Randolph Avenue
File ID #: ALH 11-363

Dear Mr. Stieber:

This is to confirm that on March 15, 2011 at the Property Code Hearing, Marcia Moermond, Legislative Hearing Officer, recommended denying the appeal on the egress windows unless you can provide photographs showing the windows to be at least 16 inches high. Upon reviewing the photographs, if the windows do not meet the requirement, Ms. Moermond will grant an extension for 90 days to bring the windows into compliance and contest the matter further at the City Council public hearing.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Pat Fish (email)
File