



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

RECEIVED

NOV 16 2015

CITY CLERK

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

We need the following to process your appeal:

- ☐ \$25 filing fee (non-refundable) (payable to the City of Saint Paul) (if cash: receipt number check # 2258)
 - ☐ Copy of the City-issued orders/letter being appealed
 - ☐ Attachments you may wish to include
 - ☐ This appeal form completed
 - ☐ Walk-In OR ☐ Mail-In
- for abatement orders only: ☐ Email OR ☐ Fax

HEARING DATE & TIME

(provided by Legislative Hearing Office)

Tuesday, November 24 2015

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 705 Jenks Ave City: St. Paul State: Mn Zip: 55106

Appellant/Applicant: Judy E. Adams Email: leadpreventionlady@yahoo.com

Phone Numbers: Business _____ Residence _____ Cell: 612-227-6965

Signature: J. Evelyn Adams Date: 11/16/15

Name of Owner (if other than Appellant): _____

Mailing Address if Not Appellant's: _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☒ Fire C of O Deficiency List/Correction
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other (Fence Variance, Code Compliance, etc.)

I bought this 4 Bedroom home for "Retail" \$165,000 in Dec 2014. Prior Inspections did not sight 2 Basement bedrooms w/ egress windows + closets as being in violation. This alteration would reduce the value of my home from a 4 to a 2 Bedroom. The records prior to 2010 have been ordered to be pulled to copy. A call into Steven Uhl has been made to discuss a variance.

Revised 8/11/2014



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989
Saint Paul, MN 55101-1806 Fax: 651-266-8951

November 6, 2015

DENNIS SCHMIDT
2446 12TH AVE E
NO ST PAUL MN 55109-2418

CORRECTION NOTICE - COMPLAINT INSPECTION

RE: 705 JENKS AVE
Ref. # 109303

Dear Property Representative:

An inspection was made of your building on November 6, 2015 in response to a referral. You are hereby notified that the following deficiency list must be corrected immediately.

A re-inspection will be made on December 7, 2015 at 12:30 pm.

Failure to comply may result in a criminal citation or revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

DEFICIENCY LIST

1. Basement - North Bedroom - SPLC 34.13 (3), SPLC 34.17 (2) - Reduce and maintain the number of occupants in the sleeping rooms to: The ceiling height is too low, it is at 6'4" and has the heat duct work running through the room that is in closed.
2. Basement - South Bedroom - SPLC 34.13 (3), SPLC 34.17 (2) - Reduce and maintain the number of occupants in the sleeping rooms to:-The ceiling height is at 6'8" and has a heat duct that is running through the unit that is in closed.
3. Interior - Throughout - SPLC 34.13 (2), (3), SPLC 34.17 (2) - Reduce and maintain the number of occupants in the unit to:-The unit can only have 4 or under unrelated adults living there.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd,
Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: brian.schmidt@ci.stpaul.mn.us or call me at 651-266-8981 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Brian Schmidt
Fire Inspector

Ref. # 109303



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

April 20, 2010

DENNIS SCHMIDT
2446 12TH AVE E
NO ST PAUL MN 55109-2418

FIRE INSPECTION CORRECTION NOTICE

RE: 705 JENKS AVE
Ref. #109303
Residential Class: B

Dear Property Representative:

Your building was inspected on April 20, 2010 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on May 20, 2010 at 10:00 am.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. EXTERIOR - SPLC 34.09 (2), 34.32(2) - Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.-Repair front concrete steps up from sidewalk, in a professional manner.
2. INTERIOR - EAST SIDE OF HOUSE - SPLC 34.14 (2) f - Provide and maintain a minimum of 1 foot candle at the grade level of exterior exits and entryways for security. This work may require a permit(s). Call DSI at (651) 266-9090.

3. INTERIOR - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.
4. INTERIOR - MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.
5. INTERIOR - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.-Extension cord found in downstairs bedroom two.
6. INTERIOR - MSFC 605.4 - Discontinue use of all multi-plug adapters.-Multi-plug adapter found in upstairs bedroom two.
7. INTERIOR - MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.-Immediately provide Carbon Monoxide Alarm for upstairs sleeping areas.
8. INTERIOR - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the walls in an approved manner.-Repair crack in wall above bathroom window frame, in a professional manner.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: kelly.booker@ci.stpaul.mn.us or call me at 651-266-8985 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Kelly Booker
Fire Inspector

Reference Number 109303



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989
Saint Paul, MN 55101-1806 Fax: 651-266-8951

January 31, 2011

DENNIS SCHMIDT
2446 12TH AVE E
NO ST PAUL MN 55109-2418

CORRECTION NOTICE - COMPLAINT INSPECTION

RE: 705 JENKS AVE
Ref. # 109303

Dear Property Representative:

An inspection was made of your building on January 31, 2011 in response to a referral. You are hereby notified that the following deficiency list must be corrected immediately. A reinspection will be made on or after March 2, 2011.

Failure to comply may result in a criminal citation or revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. general - MSFC 906.1, MN Stat. 299F.361 - Provide approved fire extinguishers in accordance with the following types, sizes and locations.-Provide minimum 2A10BC fire extinguishers spaced not more than 75 feet travel distance from any point in the building to an extinguisher. They must be permanently mounted between 3 and 5 feet high in readily visible and easily accessible locations.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: scott.st.martin@ci.stpaul.mn.us or call me at 651-266-8995 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Scott St. Martin
Fire Inspector

Ref. # 109303