



# APPLICATION FOR APPEAL

RECEIVED

Saint Paul City Clerk

MAY 29 2012

10 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

CITY CLERK

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

<b>YOUR HEARING Date and Time:</b>
Tuesday, <u>6-12-12</u>
Time <u>1:30 P.M.</u>
<b>Location of Hearing:</b>
<u>Room 330 City Hall/Courthouse</u>

## Address Being Appealed:

Number & Street: 1045 Davern St City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: \_\_\_\_\_

Name of Owner (if other than Appellant): Ernest Goodman

Address (if not Appellant's): 1045 Davern St

Phone Numbers: Business \_\_\_\_\_ Residence 651-698-8945 Cell \_\_\_\_\_

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 1 replacement window that will not comply w/ Egress policy. Interior obstructions do not allow for any alteration of this opening. The home is an architectural home and the homeowner will not change operating style. Please approve.



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

## EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: May 16, 2012

APPEAL PROPERTY ADDRESS: 1045 DAVERN ST

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 12 057288

TYPE OF WINDOW Casement

NUMBER OF WINDOWS 1

<b>Total Glazed Area</b> Minimum 5 Square Feet	3.9	<b>Difference from Required Area</b>	-1.1
<b>Width of Opening</b> Minimum 20 Inches	12 1/4	<b>Difference from Required Opening</b>	-7 3/4
<b>Height of Opening</b> Minimum 24 Inches	46	<b>Difference from Required Opening</b>	+22
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	<48	<b>Difference from Maximum Height</b>	Ok

COMMENTS: N/A

Reviewed by: J Hoffman 5-16-12