



APPLICATION FOR APPEAL

RECEIVED
MAR 08 2011
CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☒ Attachments you may wish to include
- ☒ This appeal form completed

YOUR HEARING Date and Time:

Tuesday, March 22, 2011

Time 1:30 pm

Location of Hearing:

Room 330 City Hall/Courthouse

in person

Address Being Appealed:

Number & Street: 2130 Pinehurst Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Greg Naig / Home Depot Email: gnaig@thdathomeservices.com

Phone Numbers: Business 763-852-1044 Residence _____ Cell 612-290-8239

Signature: [Signature] Date: 3-8-2011

Name of Owner (if other than Appellant): Sandy Carlson

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence 612-718-2425 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☒ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other
- ☐ Other
- ☐ Other



Greg Naig
Field Manager

THD At-Home Services, Inc.

Applicable Contractor
License Numbers Available
Upon Request

656 Mendelssohn Ave.
Golden Valley, MN 55427
Phone: 763-852-1044
Fax: 763-542-8227
Cell: 612-290-8239
gnaig@THDAtHomeServices.com

Revised 8/20/2010



**You can do it.
We can help.™**

March 8, 2011

To Whom it may concern:

Home Depot At Home Services installed bedroom windows in the home at 2130 Pinehurst Ave. and would like to Appeal to keep the Double Hung window in the bedroom for the homeowner.

Thank you for your consideration on this matter.

Greg Naig

Field Supervisor with Home Depot At Home Services

612-290-8239

gnaig@thdathomeservices.com

THD At-Home Services, Inc.

656 Mendelssohn Ave. • Golden Valley, MN 55427
763-542-8826 • Fax 763-542-8227 • Toll Free 866-718-7092



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 12, 2010

APPEAL PROPERTY ADDRESS: 2130 PINEHURST AVE

APPLICANT NAME: HOME DEPOT AT HOME SERVICES THE

PHONE NUMBER: 651-266-9025

PERMIT NUMBER: 10 506200

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2 windows in two bedrooms.

Total Glazed Area	6.8 Sq. Ft.	Difference from Required Area	1.1 Sq. Ft.
Width of Opening	23.5"	Difference from Required Opening	+3.5"
Height of Opening	20"	Difference from Required Opening	- 4"
Height of Opening to Finished Floor	36	Difference from Maximum Height	8"

COMMENTS: Windows in 2 bedrooms do not meet the St. Paul Egress code. For height of opening.

Please call

651-266-8688

Reviewed by: Michael A. Palm

*TO Set up for the Appeal
of the window's installed
in the Bedrooms.*