



APPLICATION FOR APPEAL

RECEIVED
MAR 08 2011
CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>March 22, 2011</u>
Time <u>1:30 pm</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

in person

Address Being Appealed:

Number & Street: 1217 Alameda City: St. Paul State: MIN Zip: 55117

Appellant/Applicant: Greg Naig / Home Depot Email gnaig@thdathomeservices.com

Phone Numbers: Business 763-852-1044 Residence _____ Cell 612-290-8239

Signature: *Greg Naig* Date: 3-8-2011

Name of Owner (if other than Appellant): Tonia + Richard Stephan

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence 651-487-0181 Cell 763-218-8251

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

appeal egress window for like for like window



Greg Naig
Field Manager

THD At-Home Services, Inc.

656 Mendelssohn Ave.
Golden Valley, MN 55427
Phone: 763-852-1044
Fax: 763-542-8227
Cell: 612-290-8239

Revised 8/20/2010

Applicable Contractor License Numbers Available Upon Request



**You can do it.
We can help.™**

March 8, 2011

To Whom it may concern:

Home Depot At Home Services installed bedroom windows in the home at 1217 Alameda St. and would like to Appeal to keep the Double Hung window in the bedroom for the homeowner.

Thank you for your consideration on this matter.

A handwritten signature in cursive script that reads "Greg Naig".

Greg Naig

Field Supervisor with Home Depot At Home Services

612-290-8239

gnaig@thdathomeservices.com



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: January 19, 2011

APPEAL PROPERTY ADDRESS: 1217 ALAMEDA ST

APPLICANT NAME: HOME DEPOT AT HOME SERVICES THE

PHONE NUMBER: 651-266-9020

PERMIT NUMBER: 10 502421

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2 bedrooms

Total Glazed Area Minimum 5 Square Feet	9 sq. ft.	Difference from Required Area	+5 sq. ft.
Width of Opening Minimum 20 Inches	30"	Difference from Required Opening	+10"

Height of Opening Minimum 24 Inches	21.5"	Difference from Required Opening	-2.5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	30"	Difference from Maximum Height	+18"

COMMENTS:

Reviewed by: David Tank