

Scanned



# APPLICATION FOR APPEAL

RECEIVED  
MAY 14 2012  
CITY CLERK

**Saint Paul City Clerk**  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, 10-5-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

*E-mailed Notice 5-14-12 J. J. J.*

## Address Being Appealed:

Number & Street: 1029 Bush Ave. City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Window World Email mollym@windowworldmn.com

Phone Numbers: Business 651-770-9011 Residence: \_\_\_\_\_ Cell: \_\_\_\_\_

Signature: Molly Mathew Date: 5/8/12

Name of Owner (if other than Appellant): \_\_\_\_\_

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- ~~\_\_\_\_\_~~ Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

---

---

---

---

---

---

---

---

---

---

---



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: 5/8/12

APPEAL PROPERTY ADDRESS: 1029 Bush Ave

APPLICANT NAME: Window World PHONE NUMBER: 651-770-9011  
Molly McGrane (Customer Svc. Manager)

PERMIT NUMBER: 2011285280

TYPE OF WINDOW: Slider

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: \_\_\_\_\_

DIFFERENCE FROM REQUIRED AREA: 2.3 sq.ft

WIDTH OF OPENING: 52 5/8

DIFFERENCE FROM REQUIRED OPENING: meets egress

HEIGHT OF OPENING: 27 1/4

DIFFERENCE FROM REQUIRED OPENING: meets egress

HEIGHT OF OPENING TO FINISHED FLOOR: \_\_\_\_\_

DIFFERENCE FROM MAXIMUM HEIGHT: \_\_\_\_\_

RECOMMENDATION (IF APPLICABLE): We are asking for a variance  
on this window. The slider sash opens larger than  
the 20" requirement, it just doesn't meet the overall  
required sq. ft. area of 5.7  
\* This window was replaced like for like in style & size.

FROM: Molly McGrane

