



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 1, 2010

Marie Plourde  
33<sup>rd</sup> Company  
1800 Wooddale Dr, Ste. 10  
Woodbury, MN 55125

Re: Appeal for property at 65 Battle Creek Road.  
File ID: ALH 10-309

Dear Ms. Plourde:

This is to confirm that on October 28, 2010, Marcia Moermond, Legislative Hearing Officer reviewed your appeal in the above-referenced matter and recommended granting a 2.5-inch variance on the openable width of the egress window in the basement northeast and main floor master floor bedrooms. She recommended granting a 7.5-inch variance on the openable height of the egress window in the second bedroom.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang  
Paralegal

cc: Fire Supervisors (email)  
Pat Fish (email)

