



APPLICATION FOR APPEAL

RECEIVED

MAY 08 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

YOUR HEARING Date and Time:

Tuesday, 5-15-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 717 ORANGE AVE E. City: ST. PAUL State: MN Zip: 55106

Appellant/Applicant: LINDA J. MCKINNEY Email: LINDAMCKINNEY@ONEBOX.COM

Phone Numbers: Business 612-316-1664 Residence 651-407-0511 Cell 651-253-5859

Signature: [Handwritten Signature] Date: 5-8-2012

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

Upstairs BR window is 1 inch too short
~~name~~. Reqmt is 24" operable height x
20" operable width. Our BR window
is 23" operable height x 26 operable
width.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

April 30, 2012

LINDA J MCKINNEY
CLARKE A MCKINNEY
1958 OAK KNOLL DR
WHITE BEAR LAKE MN 55110-4263

FIRE INSPECTION CORRECTION NOTICE

RE: 717 ORANGE AVE E
Ref. #113868
Residential Class: C

Dear Property Representative:

Your building was inspected on April 30, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made after July 2, 2012.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Exterior - SPLC 34.09 (1) e, 34.32 (1) d - Provide and maintain the roof weather tight and free from defects. Repair soffit and fascia on West side of roofs.
2. Exterior - SPLC 34.09 (3), 34.32 (3) - Provide or repair and maintain the window screens throughout the building.
3. Exterior - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)-

An Equal Opportunity Employer

266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-2nd Floor Bedroom: 23 inches high by 26 inches wide openable; 44 inches high by 24 inches wide glazed.

4. Interior - MSFC 605.4 - Discontinue use of all multi-plug adapters. High draw appliances must be plugged directly into electrical outlets.-Multi plug adapters in kitchen and basement.
5. Interior - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.
6. Interior - MSFC 315.2.3 - Remove combustible storage from the fuel burning equipment rooms.
7. Interior - UMC 1346.703 - Provide 30 inches clearance around all mechanical equipment in basement.
8. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: benjamin.ellis@ci.stpaul.mn.us or call me at 651-266-8946 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Benjamin Ellis
Fire Inspector

Reference Number 113868