



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi

Code Compliance Report

December 17, 2010

FANNIE MAE C/O MN BPO/REO
2026 EAGLEWOOD CIRCL
SHAKOPEE MN 55379

Re: 101 Winnipeg Ave
File#: 10 307388 VB3

Dear Property Owner:

The following is the Code Compliance report you requested on December 06, 2010.

Please be advised that this report is accurate and correct as of the date December 17, 2010. All deficiencies identified by the City after this date must also be corrected and all codes and ordinances must be complied with. This report is valid for 365 days from December 17, 2010. This report may be used in lieu of a Truth in Housing Report required in St Paul Legislative Code 189. This building must be properly secured and the property maintained at all times.

In order to sell or reoccupy this property the following deficiencies must be corrected:

BUILDING **Inspector: Jim Seeger** **Phone: 651-266-9046**

- Tuck Point interior/exterior of foundation as necessary.
- Remove mold, mildew and moldy or water damaged materials.
- Permanently secure top and bottom of support posts in an approved manner.
- Cover water meter pit with concrete or decay resistant, screwed-down cover. Cleanouts to be flush with floor slab.
- Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return hand rail ends into a newel post or wall per attachment.
- Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary.
- Provide complete storms and screens, in good repair for all door and window openings.
- Provide functional hardware at all doors and windows

Re: 101 Winnipeg Ave
December 17, 2010
Page 2

BUILDING **Inspector: Jim Seeger** **Phone: 651-266-9046**

- Exit doors shall be capable of being opened from the inside, easily and without the use of a key. Remove all surface bolts.
- Repair or replace damaged doors and frames as necessary, including storm doors.
- Weather seal exterior doors, threshold and weather-stripping.
- Install floor covering in bathroom and kitchen that is impervious to water.
- Repair walls, ceiling and floors throughout, as necessary.
- Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present.
- Any framing members that required repair or do not meet code (where wall and ceiling covering is removed, members that are over-spanned, over-spaced, not being carried properly, door and window openings that are not adequately supported, etc.) are to be reconstructed in an approved manner.
- Install Smoke Detectors/Carbon Monoxide Detectors per MN Co Conservation Code and the MN Dept. of Labor and Industry.
- Provide major clean-up of premises.
- Repair siding, soffit, fascia, trim, etc. as necessary.
- Provide proper drainage around house to direct water away from foundation of house.
- Review all applicable codes & policies when replacing windows including egress windows for sleeping rooms.
- Remove trees which are against foundation of home.
- Openings in stair risers must be less than 4 inches.
- Remove fence from front yard, does not meet Zoning Code.
- Remove deck from second floor area on front porch roof.
- Properly repair roof overhang on front of house.
- Re-level, repair and rebuild front porch.
- Install stairs to code to second floor and repair cut up floor joist to code.
- Remove all interior wall covering and bring entire structure up to code.
- Repair front and rear porches to code.
- Replace front and rear steps.
- A building permit is required to correct the above deficiencies.

ELECTRICAL **Inspector: Dan Moynihan** **Phone: 651-266-9036**

- Ground the electrical service to the water service with a copper conductor within 5 feet of the entrance point of the water service
- Bond around water meter with a copper wire sized for the electrical service per Article 250 of the NEC
- Provide a complete circuit directory at service panel indicating location and use of all circuits

Re: 101 Winnipeg Ave
December 17, 2010
Page 3

ELECTRICAL **Inspector: Dan Moynihan** **Phone: 651-266-9036**

- Verify/install a separate 20 ampere laundry circuit and a separate 20 ampere kitchen appliance circuit
- Verify that fuse/circuit breaker amperage matches wire size
- Close openings in service panel/junction box with knock out seals, breaker blanks and/or junction boxes
- Properly strap cables and conduits in basement/ service conduit on the exterior of the house.
- Repair or Replace all broken, missing or loose light fixtures, switches and outlets, covers and plates
- Check all outlets for proper polarity and verify ground on 3-prong outlets
- Install hard-wired, battery backup smoke detector per bulletin 80-1 and other smoke detectors as required by the IRC. Also, Install carbon monoxide detector(s) within 10 feet of all bedrooms
- Properly wire exterior lights at front and back door
- Remove and or/ re-wire all illegal, improper or hazardous wiring in basement and second floor to 2008 NEC.
- Repair service mast. Purchase permit for service and at least 6 circuits.
- All added receptacles must be grounded, tamper-resistant and be on an Arc-Fault Circuit Interrupter-protected circuit.
- Any open walls or walls that are opened as part of this project must be wired to the standards of the 2008 NEC.
- All buildings on the property must meet the St. Paul Property Maintenance Code (Bulletin 80-1).
- All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING **Inspector: Denny Watters** **Phone: 651-266-9051**

- Basement - Water Heater - T and P relief discharge piping incorrect (MPC 2210 Subp. 4)
- Basement - Water Heater - Vent must be in chimney liner (IFGC 501.12)
- Basement - Water Heater - Water piping incorrect (MPC 1730 Subp. 1)
- Basement - Water Heater - gas venting incorrect (IFGC 503)
- Basement - Water Heater - not fired or in service (MPC 2180) Also, move water heater to a proper location.
- Basement - Water Meter - corroded piping; incorrect piping (MPC 0200 0.)
- Basement - Water Meter - raise meter to a minimum 12 inches above floor (MPC 2280)
- Basement - Water Meter - remove meter from pit (MPC 88.08)
- Basement - Water Piping - repair or replace all corroded, broken or leaking piping (MPC 4715.1720)
- Basement - Water Piping - run 1 inch water line from meter to first major take off (SPRWS Water Code)
- Basement - Gas Piping - run dryer vent to code (IFGC 613.1 - IMC 604.1)

Re: 101 Winnipeg Ave
December 17, 2010
Page 4

PLUMBING **Inspector: Denny Watters** **Phone: 651-266-9051**

- Basement - Soil and Waste Piping - improper connections, transitions, fittings or pipe usage (MPC 2420) first floor ceiling.
- Basement - Laundry Tub - unvented (MPC 0200 E)
- Basement - Laundry Tub - waste incorrect (MPC 2300) 1 1/2 pipe below grade.
- First Floor - Sink - fixture is broken or parts missing (MPC 0200 0.) basket strainers.
- First Floor - Sink - incorrectly vented (MPC 2500)
- Second Floor - Lavatory - unvented (MPC 0200. E)
- Second Floor - Lavatory - waste incorrect (MPC 2300)
- Second Floor - Tub and Shower - faucet is missing, broken or parts missing (MPC 0200. P.)
- Second Floor - Tub and Shower - provide anti-scald valve (MPC 1380. Subp. 5)
- Second Floor - Tub and Shower - unvented (MPC 0200. E)
- Second Floor - Tub and Shower - waste incorrect (MPC 2300) ABS/PVC
- Exterior - Lawn Hydrants - Broken or parts missing (MPC 0200 K)
- Exterior - Lawn Hydrants - Requires backflow assembly or device (MPC 2000)
- Obtain plumbing permits prior to commencement of work.

HEATING **Inspector: Jerry Hanson** **Phone: 651-266-9044**

- Install heating system to code.
- Vent clothes dryer to code.
- Provide support for gas lines to code.
- Plug, cap and/or remove all disconnected gas lines.
- Provide a window in the bathrooms with an aggregate glazing area of not less than 3 square feet, one-half of which must be openable or provide exhaust system vented to outside. A mechanical ventilation permit is required if an exhaust system is installed.
- All supply and return ducts for warm air heating system must be clean before final approval for occupancy. Provide access for inspection of inside of ducts or provide documentation from a licensed duct-cleaning contractor that the duct system has been cleaned.
- Repair and/or replace heating registers as necessary.
- Provide heat in every habitable room and bathrooms.
- Appropriate mechanical permits are required for the above work.

ZONING

1. This property is in a (n) RT1 zoning district.
2. This property was inspected as a Single Family Dwelling.

Re: 101 Winnipeg Ave
December 17, 2010
Page 5

Notes:

- See attachment for permit requirements and appeals procedure.
- This property is designed by the Vacant Buildings Department as a Category #3 which requires a \$5000.00 Performance Bond or Deposit at the time the permit is issued.
- Provide plans and specifications for any portion of the building that is to be rebuilt.
- Roof, sidewalks, etc. snow covered and could not be inspected. All must meet appropriate codes when completed.

This is a registered vacant building. In order to sell or reoccupy this building, all deficiencies listed on this code compliance report must be corrected within six (6) months of the date of this report. One (1) six-month time extension may be requested by the owner and will be considered if it can be shown that the code compliance work is proceeding and is more than fifty (50) percent complete in accordance with Legislative Code Section 33.03(f).

You may file an appeal to this notice by contacting the City Clerk's Office at 651-266-8688. Any appeal must be made in writing within 10 days of this notice. (You must submit a copy of this notice when you appeal, and pay a filing fee.)

If you have any questions regarding this inspection report, please contact Jim Seeger between 7:30 - 9:00 AM at 651-266-9046 or leave a voice mail message.

Sincerely,

James L. Seeger
Code Compliance Officer
Department of Safety and Inspections
City of Saint Paul
375 Jackson Street, Suite 220
Saint Paul MN 55101
Phone: 651-266-9046
Email: james.seeger@ci.stpaul.mn.us

JLS:ml
Attachments