



# APPLICATION FOR APPEAL

RECEIVED

NOV 22 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash; receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

<b>YOUR HEARING Date and Time:</b>	
Tuesday, <u>12/7/10</u>	
Time <u>1:30</u>	
<b>Location of Hearing:</b>	
<u>Room 330 City Hall/Courthouse</u>	

## Address Being Appealed:

Number & Street: 1200 Larpen<sup>Ave E.</sup>teur City: St Paul State: Mn Zip: 55109

Appellant/Applicant: Quare Contracting Email: production@production.com

Phone Numbers: Business 763 785 1472 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Signature] Date: 11/19/10

Name of Owner (if other than Appellant): Larry Sklaney

Address (if not Appellant's): 1200 Larpen<sup>Ave E.</sup>teur

Phone Numbers: Business \_\_\_\_\_ Residence 651 774 7894 Cell \_\_\_\_\_

## What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

We installed an insert wdw in the bedroom and did not change ~~is~~ size or opening or style. we changed a Double Hung for Double Hung.

Vinyl INSERT



Scanned

CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

*Like for  
like?*

DATE: November 1, 2010

APPEAL PROPERTY ADDRESS: 1200 LARPEN TEUR AVE E

APPLICANT NAME: QUARVE CONTRACTING INC

PHONE NUMBER: 651-266-9027

PERMIT NUMBER: 10 507490

TYPE OF WINDOW Double Hung  
NUMBER OF WINDOWS One

*Bedroom  
40 stairs. DBL Hung  
for  
10BL Hung.*

Total Glazed Area	8.3sq. ft.	Difference from Required Area	+2.6 sq. ft.2
Width of Opening	29"	Difference from Required Opening	+9"
Height of Opening	16"	Difference from Required Opening	-8"
Height of Opening to Finished Floor	OK	Difference from Maximum Height	

COMMENTS:

*Egress*

*why?*

*Inspection Failed,  
need to file Appeal  
with city clerks office  
25\$ Fee paid to  
city of St. Paul to  
get appeal approval.*

Reviewed by: Dave Nelson

*Dave Nelson*