



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

January 6, 2011

Mark Cady

VIA EMAIL: mrfixitmn@gmail.com

Re: Appeal for property at 2006 Selby Avenue
File ID: 11-12

Dear Mr. Cady:

This is to confirm that on January 4, 2011 at the Property Code Hearing, Marcia Moermond, Legislative Hearing Officer recommended granting a 1.5-inch variance on the openable height of the egress horizontal slider window in the lower unit, NE bedroom; denying the appeal on the sill height issue and the steps must be permanently affixed under the escape window and must come up from the floor within an eight inch maximum rise and a nine inch maximum run. The width should equal the width of the openable area of the window.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
Gary Jager, 383 Highpoint Curve, Maplewood, MN 55119
File

