



APPLICATION FOR APPEAL

RECEIVED

JUN 15 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

YOUR HEARING Date and Time:

Tuesday, July 12

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1324 St Clair Ave City: St Paul State: MN Zip: 55108

Appellant/Applicant: Daniel P. McGowan Email: damcgs@gmail.com

Phone Numbers: Business _____ Residence 651-698-6296 Cell 651-216-3182

Signature: Daniel P. McGowan Date: 6-15-11

Name of Owner (if other than Appellant): same

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☒ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

June 15 letter:

#4 Paint- Garage to be replaced; all painting to be done then
#3 1st fl NG 2 inches short; 2nd floor 7 and 9 inches short but glazed area is OK.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

June 15, 2011

DANIEL P MCGOWAN
PAMELA MCGOWAN
1715 PINEHURST AVE
ST PAUL MN 55116-2119

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
1324 ST CLAIR AVE

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on May 25, 2011. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. A reinspection will be made on July 12, 2011 at 10:00 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. Basement - SPLC 34.23, MSFC 110.1 - This basement is condemned as unsafe or dangerous as a sleeping area. This basement must not be used as a sleeping area until re-inspected and approved by this office.-Immediately remove all beds and bedding from the basement. This basement is not a legal sleeping area.
2. Basement stove - MFGC 409.5 - Provide an approved gas shut off valve within 6 feet of the appliance in accordance with the mechanical code. This work may require a permit(s). Call DSI at (651) 266-8989.
3. Double hung windows - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-First floor north
22 h x 29 w Glazed 8.7 sq ft
Second floor south

An Equal Opportunity Employer

17 h x 29 w Glazed 5.8 sq ft

Second floor north

15 h x 29 w Glazed 5.1 sq ft

4. Garage and house - SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-Scrape and remove chipped and peeling paint. Repaint in a professional manner.
5. Porch - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.
6. Porch - MSFC 605.4 - Discontinue use of all multi-plug adapters.
7. Porch - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway.-Reduce storage on the porch by 50 percent.
8. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
9. MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.-Immediately provide approved alarms.
10. UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work requires a permit(s). Call DSI at (651) 266-8989.
11. Provide the inspector with a completed and signed Residential Occupancy Affidavit.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector