



# APPLICATION FOR APPEAL

RECEIVED

OCT 18 2010

CITY CLERK

**Saint Paul City Clerk**

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, Oct. 26

Time 1:30

Location of Hearing:  
Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1596 McLean Ave. City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Jim & Lisa Campbell Email lcampbell02@sjm.com

Phone Numbers: Business 651-756-6634 Residence 651-735-7845 Cell 651-324-4594

Signature: [Handwritten Signature] Date: 10-1-10

Name of Owner (if other than Appellant): \_\_\_\_\_

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Inspection directed us to move dryer because it encroaches 30" to the electrical panel. The way the laundry room is designed we would have to remove the dryer in question, which currently there is one dryer for each unit on separate electricity boxes. The unit has functioned this way very efficiently since we purchased the home almost 20 years ago.

Thanks for your consideration.



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

September 22, 2010

LISA A CAMPBELL  
JIM CAMPBELL  
2024 OAKRIDGE ST  
ST PAUL MN 55119-5329

### FIRE INSPECTION CORRECTION NOTICE

RE: 1596 MCLEAN AVE  
Ref. #107050  
Residential Class: C

Dear Property Representative:

Your building was inspected on September 22, 2010 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on October 25, 2010 at 10:30 A.M..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

#### DEFICIENCY LIST

1. Downstairs - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.
2. Downstairs - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. Remove beds and or dresser that prevent exiting through escape window.
3. Downstairs - SPLC 34.09 (3) i - Provide and maintain an approved one-inch throw single cylinder deadbolt lock.-Front and rear exit doors

4. Downstairs Kitchen wall by Oven - SPLC 34.10 (5), 34.33 (4), 34.16 - Provide and maintain interior in a clean and sanitary condition.
5. Upstairs - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.
6. Upstairs - SPLC 34.09 (3) i - Provide and maintain an approved one-inch throw single cylinder deadbolt lock.-Front and Rear exit doors
7. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
8. NEC 110-26 - Provide and maintain a minimum of 36 inches clearance in front of all electrical panels.
9. UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work WILL require a permit(s). Call DSI at (651) 266-8989.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [james.thomas@ci.stpaul.mn.us](mailto:james.thomas@ci.stpaul.mn.us) or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas  
Fire Inspector

Reference Number 107050

