



APPLICATION FOR APPEAL

RECEIVED

NOV 22 2010

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 12/7/10

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1591 Mclean Ave City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersenacorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): ELAINE RAYNE

Address (if not Appellant's): 1591 MCLEAN AVE ST. PAUL MN 55106

Phone Numbers: Business _____ Residence 651-730-0999 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 3 double hung windows that will not comply w/ egress policy. Current dimensions will be 4" short in operable height. Operable width is exceeded by 13.5", overall glazed area is also exceeded. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 15, 2010

APPEAL PROPERTY ADDRESS: 1591 MCLEAN AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 922006

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 3

Total Glazed Area	12.2 sq. ft.	Difference from Required Area	+ 7.2 sq. ft.
Width of Opening	33 ½ "	Difference from Required Opening	+ 13.5"
Height of Opening	20"	Difference from Required Opening	- 4"
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS:

Reviewed by: B.H.