



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHOND: (651) 266-8560 FAX: (651) 266-8574

December 20, 2010

CORRECTION LETTER

Keith Frank  
1327 Edgerton St, Apt A  
St. Paul, MN 55130

VIA EMAIL: [keithfrankmn@gmail.com](mailto:keithfrankmn@gmail.com)

Re: Appeal for property at 1604 Euclid Street  
File ID: ALH 10-519

Dear Mr. Frank:

This is to confirm that on December 14, 2010 at the Property Code Hearing, Ms. Moermond recommended the following:

1. grant a 3-inch variance on the openable height of the egress windows in the upper unit main floor mater, northwest and northeast bedroom;
2. grant a 7-inch variance on the openable height of the egress window in the basement storage room;
3. grant a 7-inch variance on the openable height of the egress window in the lower unit west bedroom; and
4. deny the appeal on the electrical service panel in the Upper unit and grant an extension for 60 days to bring it into compliance.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang  
Legislative Hearing Coordinator

Cc: Fire Supervisors (email)  
Pat Fish (email)  
File