



APPLICATION FOR APPEAL

OCT 10 2011 Saint Paul City Clerk
CITY CLERK 310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 10-25-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

mailed 10-10-11

Address Being Appealed:

Number & Street: 1538 GRANTHAM ST. City: ST. PAUL State: MN Zip: 55108

Appellant/Applicant: VICTOR HANSON and Ann Hanson Email anniemarie210@yahoo.com

Phone Numbers: Business 612-567-7817 Residence _____ Cell 651-485-7382

Signature: [Signature] Date: 10/7/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

WE ARE DOING REPLACEMENT WINDOWS ON THE HOUSE. THE TWO WE WANT TO APPEAL MEET THE BUILDING CODE BUT NOT ST. PAUL FIRE CODE. THEY ARE COST PROHITED BY HAVING TO OPEN WALLS AND FRAME NEW HEADERS. WE ARE HOPING THESE CAN STAY DOUBLE HUNG LIKE THE REST ARE. THANK YOU.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: Oct. 7, 2011

APPEAL PROPERTY ADDRESS: 1538 GRANTHAM ST. ST. PAUL, MN.
55108

APPLICANT NAME: VICTOR HANSON PHONE NUMBER: _____

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE HUNG MARVIN

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 4.69 SQ FT DIFFERENCE FROM REQUIRED AREA: .31 SQ FT

WIDTH OF OPENING: 32 (28.56 CLEAR) DIFFERENCE FROM REQUIRED OPENING: N/A

HEIGHT OF OPENING: 56 (23.59) DIFFERENCE FROM REQUIRED OPENING: .41"

HEIGHT OF OPENING TO FINISHED FLOOR: 36" DIFFERENCE FROM MAXIMUM HEIGHT: N/A

SEE ATTACHED SHEET

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____

Brigette Smith

From: Bernie OConnor [boconnor@shawstewartlumberco.com]
Sent: Wednesday, September 28, 2011 4:39 PM
To: Tim Pautz
Cc: Marty Ruddy; Gary Short
Subject: Hanson windows
Attachments: TERRA FIRMA-HANSON #4 09-28-2011.pdf

Tim,
Here is the revised Hanson residence windows. I have deleted one RO 32" x 56" single window double hung window from the baby's room & the master bedroom. I have also changed the one music room to an RO of 34" x 56" so it meets St Paul's fire code egress. (I add just 1/8" to the width.)
Both on the windows in the baby's room and master bedroom windows have an RO of 32" X 56"; the total egress opening of 4.69 SQ FT; clear egress opening width of 28.56"; and clear egress opening height of 23.59".
Please let me know if you have any other questions.
Thanks,

Bernie O'Connor
Contractor Sales
Shaw-Stewart Lumber Company
612-378-1520 Yard
612-378-1484 Fax
612-594-6151 Direct
612-685-6939 Cell
E-Mail: boconnor@shawstewartlumberco.com
Website: www.shawstewartlumberco.com