

RECEIVED

OCT 13 2010

CITY CLERK



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

1. Address of Property being Appealed: <u>1446 Hythe Street</u>	2. Number of Dwelling Units: <u>SFD</u>	3. Date of Letter Appealed: <u>10-12-10</u>
--	--	--

4. Name of Owner: Catherine Jordan

Address: 1446 Hythe Street City: St. Paul State: MN Zip: 55108

Phone Numbers: Business 612-625-7891 Residence 651-647-1660 Cellular _____

Signature: _____

5. Appellant / Applicant (if other than owner): Renewal by Andersen

Address: 1920 W City Rd C City: Roseville State: MN Zip: 55113

Phone Numbers: Business 651-264-4088 Residence _____ Cellular _____

Signature: Bryan Horton

6 State specifically what is being appealed and why (Use an attachment if necessary):

We are appealing to replacement Double Hung windows that
will not comply w/ Egress policy. These windows are located
w/in 3 separate bedrooms but all are identical in size.
The existing height opening will be short by 2 1/8". Operable
height will be exceeded by over 8". Please Approve

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>10/14/10</u>	Fee Received: <u>25</u>	Receipt Number:	Date of Hearing: <u>10/26/10 1:30</u>
-----------------------------------	----------------------------	-----------------	--

Revised 4/25/2007



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 12, 2010

APPEAL PROPERTY ADDRESS: 1446 HYTHE ST

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 908774

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 6

Total Glazed Area	11.3 sq. ft.	Difference from Required Area	+ 6.3 sq. ft.
Width of Opening	28 3/8 "	Difference from Required Opening	+ 8 3/8 "
Height of Opening	21 7/8 "	Difference from Required Opening	- 2 1/8 "
Height of Opening to Finished Floor	NA	Difference from Maximum Height	NA

COMMENTS: Do to information provided above recommend approval.

Reviewed by: B.H.