



APPLICATION FOR APPEAL

RECEIVED

JUL 18 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 8-9-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

201K-19

Address Being Appealed:

Number & Street: 1163 Edmund Ave City: St. Paul State: MN Zip: 55104

Appellant/Applicant: Victoria Boller LaBerge Email vlaberge@visi.com

Phone Numbers: Business _____ Residence 651-646-5497 Cell 651-295-8767

Signature: Victoria Boller LaBerge Date: 7/18/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Egress Window Non-compliance



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: July 18, 2011

APPEAL PROPERTY ADDRESS: 1163 EDMUND AVE

APPLICANT NAME: THE WINDOW STORE HOME IMPROVEMENTS INC

PHONE NUMBER: 612-353-5780

PERMIT NUMBER: 11 251914

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 4

Total Glazed Area Minimum 5 Square Feet	2.96	Difference from Required Area	-2.04
Width of Opening Minimum 20 Inches	21.344	Difference from Required Opening	OK
Height of Opening Minimum 24 Inches	20"	Difference from Required Opening	-4"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	26 1/2"	Difference from Maximum Height	21 1/2"

COMMENTS:

Reviewed by: DD 7-18-11



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: July 18, 2011

APPEAL PROPERTY ADDRESS: 1163 EDMUND AVE
APPLICANT NAME: THE WINDOW STORE HOME IMPROVEMENTS INC
PHONE NUMBER: 612-353-5780
PERMIT NUMBER: 11 251914
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	3.242 sq. ft.	Difference from Required Area	-1.758 sq. ft.
Width of Opening Minimum 20 Inches	23.344	Difference from Required Opening	OK
Height of Opening Minimum 24 Inches	20"	Difference from Required Opening	-4"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	26 1/2"	Difference from Maximum Height	+21 1/2"

COMMENTS:

Reviewed by: DD 7-18-11