



# APPLICATION FOR APPEAL

RECEIVED  
FEB 09 2012  
CITY CLERK  
RECEIVED  
FEB 09 2012  
CITY CLERK

**Saint Paul City Clerk**  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

**The City Clerk needs the following to process your appeal:**

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

**YOUR HEARING Date and Time:**

Tuesday, 2-21-12

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1086 Galtier St. City: St. Paul State: MN Zip: 55107

Appellant/Applicant: Angen Xiong Email angen\_xiong@yahoo.com

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell (651) 621-4512

Signature: [Signature] Date: 2-9-12

Name of Owner (if other than Appellant): \_\_\_\_\_

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O \_\_\_\_\_
- Summary/Vehicle Abatement \_\_\_\_\_
- Fire C of O Deficiency List \_\_\_\_\_
- Fire C of O: Only Egress Windows \_\_\_\_\_
- Code Enforcement Correction Notice \_\_\_\_\_
- Vacant Building Registration \_\_\_\_\_
- Other Window x 1 \_\_\_\_\_
- Other \_\_\_\_\_
- Other \_\_\_\_\_



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: February 9, 2012

APPEAL PROPERTY ADDRESS: 1086 GALTIER ST

APPLICANT NAME: ANGEN XIONG

PHONE NUMBER: 651-621-4512

PERMIT NUMBER: 11 266747

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

<b>Total Glazed Area</b> Minimum 5 Square Feet	7	<b>Difference from Required Area</b>	+2
<b>Width of Opening</b> Minimum 20 Inches	21	<b>Difference from Required Opening</b>	+1
<b>Height of Opening</b> Minimum 24 Inches	18	<b>Difference from Required Opening</b>	-6
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	<48	<b>Difference from Maximum Height</b>	Ok

COMMENTS: N/A

Reviewed by: J Hoffman 2-9-12