

## Vang, Mai (CI-StPaul)

---

**From:** Tonnancour, Brian (CI-StPaul)  
**Sent:** Wednesday, April 09, 2014 8:27 AM  
**To:** Shaff, Leanna (CI-StPaul)  
**Cc:** Vang, Mai (CI-StPaul)  
**Subject:** 126 Sycamore

Leanna,

I apologize for the pictures not being in the file for this property. I attempted to load them in the new AMANDA Wed and thought they were in there. I have now loaded them and checked to ensure they are there.

The fridge in this kitchen is a rather large full sized refrigerator. The kitchen is an expansive space for the size of the property and with a little constructive thinking one could think of a few different ways to arrange the kitchen to allow for access to the panel. Please take a look at the pictures and you will see my concern with this arrangement. Thanks!



### **Brian Tonnancour**

#### ***Fire Inspector***

Department of Safety and Inspections (DSI)

375 Jackson St. Ste 220

Saint Paul, MN 55101

P: 1-651-266-8955

F: 1-651-266-8951

[brian.tonnancour@ci.stpaul.mn.us](mailto:brian.tonnancour@ci.stpaul.mn.us)

The Most Livable  
City in America



Making Saint Paul the Most Livable City in America