



APPLICATION FOR APPEAL

RECEIVED
NOV 18 2011
CITY CLERK
Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 12-6-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: B Crocus Hill City: St. Paul State: MIN Zip: 55102

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Claudia Gumbiner

Address (if not Appellant's): B Crocus Hill

Phone Numbers: Business _____ Residence 562-208-8422 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 2 casement window replacements that will not comply w/ Egress policy. Operable width will be short by 2". Operable height and overall glazed area criteria is met or exceeded. Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 14, 2011

APPEAL PROPERTY ADDRESS: 8 CROCUS HILL

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 299738

TYPE OF WINDOW Casement

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	6.0	Difference from Required Area	+1
Width of Opening Minimum 20 Inches	18	Difference from Required Opening	-2
Height of Opening Minimum 24 Inches	48.5	Difference from Required Opening	+24.5
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	ok

COMMENTS: N/A

Reviewed by: J Hoffman 11-14-11