

MAR 01 2011

RECEIVED

MAR 01 2011

CITY CLERK

CITY CLERK



# APPLICATION FOR APPEAL

Saint Paul City Clerk  
15 W. Kellogg Blvd., 310 City Hall  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8688

mailed 3-1-11

1. Address of Property being Appealed: 865 Hazelwood St.	2. Number of Dwelling Units:	3. Date of Letter Appealed: 2/4/11
---	------------------------------	---------------------------------------

4. Name of Owner: Wangthor Vang  
 Address: 865 Hazelwood St. city: St. Paul State: MN Zip: 55106  
 Phone Numbers: Business \_\_\_\_\_ Residence 651-207-5189 Cellular 651-235-7124  
 Signature: [Signature]

5. Appellant / Applicant (if other than owner): Budget Exteriors  
 Address: \_\_\_\_\_ Ci 8017 Nicollet Ave S. Zip: \_\_\_\_\_  
Bloomington, MN 55420  
 Phone Numbers: Business \_\_\_\_\_ PH: (952) 887-1613  
 F: (952) 887-1659  
 Signature: [Signature]

6 State specifically what is being appealed and why (Use an attachment if necessary):

TWO EXISTING DOUBLE HUNG WINDOWS IN BLOCK BASEMENT WALL WERE REPLACED WITH 2 CASEMENT BROSS STYLE WINDOWS IN 2 SLEEPING AREAS. HOMEOWNER UNABLE TO ACHIEVE ENLARGEMENT OF OPENING TO MEET THE 48" HIGH REQUIREMENT BUND IN THE NEW CODE. WE HAVE IMPROVED THE BROSS ABILITIES OF THESE TWO OPENINGS BY 100% OVER THE ORIGINAL WINDOWS ALONG WITH BEING MORE ENERGY EFFICIENT FOR THE CLIENT.

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received: <u>3/1/11</u>	Fee Received: <u>25pd</u>	Receipt Number:	Date of Hearing: <u>3-15-11 11:30</u>
---------------------------------	------------------------------	-----------------	--

Revised 4/25/2007



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

## EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: February 4, 2011

APPEAL PROPERTY ADDRESS: 865 HAZELWOOD ST

APPLICANT NAME: BUDGET EXTERIORS INC

PHONE NUMBER: 651-266-9027

PERMIT NUMBER: 10 895292

TYPE OF WINDOW Casement

NUMBER OF WINDOWS TWO

<b>Total Glazed Area</b> Minimum 5 Square Feet	OK	<b>Difference from Required Area</b>	
<b>Width of Opening</b> Minimum 20 Inches	OK	<b>Difference from Required Opening</b>	
<b>Height of Opening</b> Minimum 24 Inches	OK	<b>Difference from Required Opening</b>	
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	56"	<b>Difference from Maximum Height</b>	+8"

COMMENTS:

Reviewed by: David Nelson