



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

RECEIVED
JUL 18 2011
CITY CLERK

YOUR HEARING Date and Time:
Tuesday, 8-2-11
Time 1:30
Location of Hearing:
Room 330 City Hall/Courthouse
emailed 7-18-11

Address Being Appealed:

Number & Street: 1958 Saunders Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Max & Elizabeth Schultz

Address (if not Appellant's): Same as appealed address

Phone Numbers: Business _____ Residence 651-587-9870 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing the replacement of 2 double hungs that will not comply w/ Egress Policy. Operable height is 19", operable width is 23". Job also has 4 other replacements that will not comply but should be approved as an equivalency to the policy. Please Approve

Revised 8/20/2010



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: July 6, 2011

APPEAL PROPERTY ADDRESS: 1958 SAUNDERS AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 247331

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 4

Total Glazed Area Minimum 5 Square Feet	12.75 sq. ft.	Difference from Required Area	+7.75 sq. ft.
Width of Opening Minimum 20 Inches	30"	Difference from Required Opening	+10"
Height of Opening Minimum 24 Inches	23 3/8"	Difference from Required Opening	-5/8"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	ok	Difference from Maximum Height	ok

COMMENTS: Based on the information provided above recommend approval.

Reviewed by: dd 7-6-11



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: July 6, 2011

APPEAL PROPERTY ADDRESS: 1958 SAUNDERS AVE
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 247331
TYPE OF WINDOW: Double Hung
NUMBER OF WINDOWS: 2

Total Glazed Area Minimum 5 Square Feet	8 sq. ft.	Difference from Required Area	+3 sq. ft.
Width of Opening Minimum 20 Inches	23"	Difference from Required Opening	+3"
Height of Opening Minimum 24 Inches	19 3/8"	Difference from Required Opening	-4 5/8"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	ok	Difference from Maximum Height	ok

COMMENTS: Based on the information provided above recommend approval.

Reviewed by: dd 7-6-11