



APPLICATION FOR APPEAL

RECEIVED
MAY 16 2012
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- Copy of the City-issued orders or letter which
are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

<i>YOUR HEARING Date and Time:</i>
Tuesday, <u>6-5-12</u>
Time <u>1:30 P.M.</u>
<i>Location of Hearing:</i>
<u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 2184 Larry Ho Drive City: St. Paul State: MN Zip: 55109

Appellant/Applicant: Beissel Window and Siding, Co Email jeff@beisselwindows.com

Phone Numbers: Business 651-451-6835 Residence _____ Cell _____

Signature: *Jeff W Beissel* Date: 5/15/12

Name of Owner (if other than Appellant): John and Sharon O'Connell

Address (if not Appellant's): 2184 Larry Ho Drive

Phone Numbers: Business _____ Residence 651-738-8310 Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other Bedroom Egress



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: May 11, 2012

APPEAL PROPERTY ADDRESS: 2184 LARRY HO DRIVE
APPLICANT NAME: BEISSEL WINDOW & SIDING CO
PHONE NUMBER: 651-451-6835
PERMIT NUMBER: 12 053554
TYPE OF WINDOW DOUBLE HUNG
NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	7.75	Difference from Required Area	+2.75
Width of Opening Minimum 20 Inches	31 3/8	Difference from Required Opening	+11 3/8
Height of Opening Minimum 24 Inches	16 5/8	Difference from Required Opening	-7 3/8
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	OK

COMMENTS:

Reviewed by: R REHN

