



# APPLICATION FOR APPEAL

RECEIVED  
MAR 08 2011  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- XX \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- XX Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- XX This appeal form completed

YOUR HEARING Date and Time:

Tuesday, March 22, 2011

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

## Address Being Appealed:

Number & Street: 1184 Goodrich Avenue City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Appellant/Applicant: Joanne Burr  
Window Concepts of Minnesota Email \_\_\_\_\_  
990 Lone Oak Road, Suite #114, Eagan, MN 55121

Phone Numbers: Business 952-883-0476 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Name of Owner (if other than Appellant): Andreas Schramm

Address (if not Appellant's): \_\_\_\_\_

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O \_\_\_\_\_
- Summary/Vehicle Abatement \_\_\_\_\_
- Fire C of O Deficiency List \_\_\_\_\_
- Fire C of O: Only Egress Windows \_\_\_\_\_
- Code Enforcement Correction Notice \_\_\_\_\_
- Vacant Building Registration \_\_\_\_\_
- XX Other Egress Window Non-Comp. Det. \_\_\_\_\_
- Other \_\_\_\_\_
- Other \_\_\_\_\_

25.00



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: March 1, 2011

*Andreas Schramm*

APPEAL PROPERTY ADDRESS: 1184 GOODRICH AVE

APPLICANT NAME: WINDOW CONCEPTS OF MINNESOTA INC

PHONE NUMBER: 651-266-9020

PERMIT NUMBER: 10 933083

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1 Bedroom

<b>Total Glazed Area</b> Minimum 5 Square Feet	6.5 sq. ft.	<b>Difference from Required Area</b>	+1.5 sq. ft. ok
<b>Width of Opening</b> Minimum 20 Inches	32"	<b>Difference from Required Opening</b>	+8" ok
<b>Height of Opening</b> Minimum 24 Inches	19.5"	<b>Difference from Required Opening</b>	-4.5"
<b>Height of Opening to Finished Floor</b> Maximum 48 Inches for Existing Openings	28"	<b>Difference from Maximum Height</b>	+20"ok

COMMENTS:

Reviewed by: David Tank