



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

RECEIVED

OCT 13 2010

CITY CLERK

1. Address of Property being Appealed: <u>366 Johnson Parkway</u>	2. Number of Dwelling Units: <u>SFD</u>	3. Date of Letter Appealed: <u>10-8-10</u>
--	--	---

4. Name of Owner: TIM OLSEN
 Address: 366 Johnson Parkway City: St. Paul State: MN Zip: 55106
 Phone Numbers: Business _____ Residence 651-793-4662 Cellular _____
 Signature: _____

5. Appellant / Applicant (if other than owner): Renewal by Andersen
 Address: 1920 W GY Rd C City: Roseville State: MN Zip: 55113
 Phone Numbers: Business 651-264-4088 Residence _____ Cellular _____
 Signature: Bryan Horton

6 State specifically what is being appealed and why (Use an attachment if necessary):
We are appealing 1 casement picture window located in the master bedroom. With the existing dimensions the opening width will be short by 2 1/4". Operable height is exceeded by 5 1/2". Please Approve

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only			
Date Received: <u>10/13/10</u>	Fee Received: <u>25</u>	Receipt Number:	Date of Hearing: <u>Oct. 19 1:30</u>

Revised 4/25/2007



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: October 8, 2010

APPEAL PROPERTY ADDRESS: 366 JOHNSON PKWY
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-266-9071
PERMIT NUMBER: 10 907627
TYPE OF WINDOW: Casement picture window
NUMBER OF WINDOWS: 1

Total Glazed Area	18.8	Difference from Required Area	+13.8
Width of Opening	17.75	Difference from Required Opening	-2.25
Height of Opening	29.5	Difference from Required Opening	5.5
Height of Opening to Finished Floor	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above, approval is recommended. 10-8-10 rr

Reviewed by: Rehn