



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

February 17, 2011

Cynthia Mueller
546 Stone Rd
Mendota Heights, MN 55120

VIA EMAIL: cyndimuller@yahoo.com

Re: Appeal for property at 285 Cliff Street #4
File ID: ALH 11-251

Dear Ms. Mueller:

This is to confirm that on February 8, 2011 the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 6-inch variance on the openable height of the egress window in Unit 4, north bedroom and a 2.5-inch variance on the openable height of the egress window in Unit 4, west bedroom.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
File

