



APPLICATION FOR APPEAL

RECEIVED

NOV 11 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:
Tuesday, <u>11-22-11</u>
Time <u>1:30</u>
Location of Hearing:
Room 330 City Hall/Courthouse

Submitted 11/21/11 J. J. J.

Address Being Appealed:

Number & Street: 1013 Grotto St N City: St. Paul State: MN Zip: 55103

Appellant/Applicant: Installation Masters, Inc Email: penny@InstallationMastersinc.com

Phone Numbers: Business 763-780-1212 Residence 763-780-6280 Cell 612-282-3744

Signature: [Signature] Date: 11-9-11

Name of Owner (if other than Appellant): Tony and Katy Harms

Address (if not Appellant's): 1013 Grotto

Phone Numbers: Business _____ Residence 612-250-1510 Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688 ✓
FAX: 651-266-8574

DATE: October 31, 2011

APPEAL PROPERTY ADDRESS: 1013 GROTTO ST N

APPLICANT NAME: INSTALLATION MASTERS INC

PHONE NUMBER: 763-780-1212

PERMIT NUMBER: 11 256177

TYPE OF WINDOW

NUMBER OF WINDOWS 3 (one in ea. bedroom)

Total Glazed Area Minimum 5 Square Feet	1) 12.5 sq.ft. ; 2) (2) @ 28"	Difference from Required Area	1) + 6.8sq. ft.; 2 (2)@ +.4.2 sq.ft.
Width of Opening Minimum 20 inches	1) 36"; 2) (2)@ 28"	Difference from Required Opening	1) +16"; 2) (2)@ +12"
Height of Opening Minimum 24 Inches	3 @ 17"	Difference from Required Opening	3 @ -3"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36"	Difference from Maximum Height	+ 8"

COMMENTS:

Check \$25.00

Reviewed by: Virgil Thomas