



CITY OF SAINT PAUL  
*Christopher B. Coleman, Mayor*

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

July 28, 2014  
SCOTT BECK  
PROPERTY MANAGER  
1611 COUNTY ROAD B W STE 104  
ROSEVILLE MN 55113-3907

## **NOTICE OF CONDEMNATION UNFIT FOR HUMAN HABITATION ORDER TO VACATE**

RE: 870 GALTIER ST  
Ref. # 121871

Dear Property Representative:

Your building was inspected on July 28, 2014.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed or the building vacated by the re-inspection date.

A reinspection will be made on or after August 27, 2014.

**CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.**

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

### **DEFICIENCY LIST**

1. Interior - Throughout - SPLC 34.23, MSFC 110.1 - This occupancy is condemned as unfit for human habitation. This occupancy must not be used until re-inspected and approved by this office.-  
Restore water service to the building or vacate by 7/28/2014.

2. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
3. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: [scott.perrier@ci.stpaul.mn.us](mailto:scott.perrier@ci.stpaul.mn.us) or call me at 651-266-8995 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

Scott Perrier  
Fire Inspector  
Ref. # 121871

cc: Housing Resource Center  
Force Unit