



APPLICATION FOR APPEAL

RECEIVED
APR 20 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 5-3-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

MAIL 4-30-11

Address Being Appealed:

Number & Street: 2156 NOKOMIS AV City: ST. PAUL State: MN Zip: _____

Appellant/Applicant: KEVEN STEEN Email KSteen@wellingtonwindow.com

Phone Numbers: Business 952-933-6300 Residence _____ Cell 952-451-5412

Signature: *Keven Steen* Date: 4-4-11

Name of Owner (if other than Appellant): ARTHUR LACHAPPELLE

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows THE OPENING HEIGHT OF 3 WINDOWS
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other _____
- Other _____
- Other _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: January 4, 2011

APPEAL PROPERTY ADDRESS: 2156 NOKOMIS AVE

APPLICANT NAME: WELLINGTON WINDOW & DOOR COMPANY

PHONE NUMBER: 651-266-9027

PERMIT NUMBER: 10 930922

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS Three

Total Glazed Area Minimum 5 Square Feet	7.8 sq.ft.	Difference from Required Area	+2.1 sq.ft.
Width of Opening Minimum 20 Inches	33"	Difference from Required Opening	+13"
Height of Opening Minimum 24 Inches	17"	Difference from Required Opening	-7"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	OK	Difference from Maximum Height	

COMMENTS:

Reviewed by: David Nelson