

Vang, Mai (CI-StPaul)

From: Moermond, Marcia (CI-StPaul)
Sent: Tuesday, April 12, 2022 5:11 PM
To: Vang, Mai (CI-StPaul); Zimny, Joanna (CI-StPaul)
Subject: FW: APPEAL LANGUAGE
Attachments: SAFETY INSPECTION - APPEAL LANGUAGE.docx

Can this email and attachment be attached to the record?

From: Barry Kostyk <bwkostyk@comcast.net>
Sent: Monday, April 11, 2022 3:28 PM
To: Moermond, Marcia (CI-StPaul) <marcia.moermond@ci.stpaul.mn.us>
Cc: Neis, Adrian (CI-StPaul) <adrian.neis@ci.stpaul.mn.us>; Barry Kostyk <bwkostyk@comcast.net>
Subject: APPEAL LANGUAGE

Think Before You Click: This email originated outside our organization.

Marcia, I received an email notification of your recommendation regarding my appeal being presented to the City Council on April 20th.

The language regarding my appeal which is presented is something I (and other future owners) will have to live with and so would like to propose the attached.

Is it acceptable?

-Barry

For 351 Hope Street, in the basement room and laundry area, a fire-rated floor and ceiling construction does not need to be provided, conditioned on the interconnected, hard-wired smoke alarm system in the basement and building being maintained and there being no combustible storage in basement areas not having a fire-rated floor/ceiling/wall construction.