

Scanned



WP 12-63 APPLICATION FOR APPEAL

RECEIVED
JUN 01 2012
CITY CLERK
Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

RECEIVED
~~MAY 14~~ 2012
CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>6-19-12</u>
Time <u>1:30 pm</u>
Location of Hearing: <u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

Number & Street: 915 White Bear Ave. N
11031 Birmingham St. City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Window World Email mollymc@windowworldmn.com

Phone Numbers: Business 651-770-9011 Residence _____ Cell _____

Signature: Molly McNamee Date: 5/8/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- ~~Other~~ Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Scanned



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

RECEIVED
JUN 01 2012
CITY CLERK

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 5/8/11

T & M Properties

APPEAL PROPERTY ADDRESS: 905 WHITE BEAR AVE N

APPLICANT NAME: WINDOW WORLD

PHONE NUMBER: 651-770-9315

PERMIT NUMBER: 11 132422

TYPE OF WINDOW Casement

NUMBER OF WINDOWS 5- Five

Total Glazed Area Minimum 5 Square Feet	OK	Difference from Required Area	OK
Width of Opening Minimum 20 Inches	OK	Difference from Required Opening	OK
Height of Opening Minimum 24 Inches	OK	Difference from Required Opening	OK
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	54"	Difference from Maximum Height	+6"

COMMENTS:

they Built steps for the windows

Reviewed by: David Nelson