



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

355

April 30, 2014

10-515142

White Oak Investment Group LLC
1098 Arcade St
Saint Paul MN 55106-2602

White Oak Investment Group LLC
842 University Ave W
Saint Paul MN 55104-4807

The Relocation Center
700 Twelve Oaks Center Drive #235
Wayzata MN 55391

Thomas Phung
1600 128th Lane NW
Coon Rapids MN 55448

Order to Abate Nuisance Building(s)

Dear Sir or Madam:

The Vacant/Nuisance Buildings Unit, Department of the Department of Safety and Inspections, Division of Code Enforcement, hereby declares the premises located at:

1093 ARCADE ST

With the following Historic Preservation information: NONE

and legally described as follows, to wit:

Oak Ville Park N 34 Ft Of E 3o Ft Of Lot 17 And Of N 34 Ft Of Lot 18 Blk 24

to comprise a nuisance condition in violation of the Saint Paul Legislative Code, Chapter 45.02, and subject to demolition under authority of Chapter 45.11.

On April 16, 2014 a Building Deficiency Inspection Report was compiled and the following conditions were observed.

This list of deficiencies is not necessarily all the deficiencies present at this time. This building(s) is subject to the restrictions of Saint Paul Ordinance Chapter 33.03 and shall not again be used for occupancy until such time as a Certificate of Compliance or a Certificate of Occupancy has been issued. All repairs must be in accordance with appropriate codes. Changes or additions to the electrical system, mechanical system, or the plumbing system may necessitate updating or upgrading the systems involved.

This is a one-story, wood frame, duplex.

The following is excerpted from the May 17, 2011 Code Compliance Inspection Report:

BUILDING

- Dry out basement and eliminate source of moisture.
- Remove mold, mildew and moldy or water damaged materials.
- Permanently secure top and bottom of support posts in an approved manner.
- All penetrations required to have property intumescent device or caulk (per current building codes).
- Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return hand rail ends into a newel post or wall per attachment.
- Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary.
- Provide complete storms and screens, in good repair for all door and window openings.
- Exit doors shall be capable of being opened from the inside, easily and without the use of a key. Remove all surface bolts.
- Repair or replace damaged doors and frames as necessary, including storm doors.
- Weather seal exterior doors, threshold and weather-stripping.
- Install floor covering in bathroom and kitchen that is impervious to water.
- Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present.
- Air-seal and insulate attic/access door.
- Install Smoke Detectors/Carbon Monoxide Detectors per MN Co Conservation Code and the MN Dept. of Labor and Industry.
- Provide major clean-up of premises.
- Repair siding, soffit, fascia, trim, etc. as necessary.
- Provide proper drainage around house to direct water away from foundation of house.
- Provide proper drainage around house to direct water away from foundation of garage.
- Review all applicable codes & policies when replacing windows including egress windows for sleeping rooms.
- Openings in stair risers must be less than 4 inches.
- Replace front steps and landing and replace rotted rim joist under entry at front of house and re level.
- Repair rear broken steps and install northwest landing steps.
- First floor bathroom install new tub surround and deal properly.
- Repair wall in back of vanity cabinet.
- Replace all carpet and floor coverings.
- Repair or replace fence.
- Install vapor barrier to crawl space.
- A building permit is required to correct the above deficiencies.

ELECTRICAL

- Ground the electrical service to the water service with a copper conductor within 5 feet of the entrance point of the water service
- Bond around water meter with a copper wire sized for the electrical service per Article 250 of the NEC
- Provide a complete circuit directory at service panel indicating location and use of all circuits
- verify/install a separate 20 ampere laundry circuit and a separate 20 ampere kitchen appliance circuit
- Verify that circuit breaker amperage matches wire size
- Close openings in service panel/junction box with knock out seals, breaker blanks and/or junction boxes
- Ground bathroom light in first second bathroom
- Repair or Replace all broken, missing or loose light fixtures, switches and outlets, covers and plates
- Check all outlets for proper polarity and verify ground on 3-prong outlets
- Remove any 3-wire ungrounded outlets and replace with 2-wire or ground 3-wire to code
- Install hard-wired, battery backup smoke detector per bulletin 80-1 and other smoke detectors as required by the IRC. Also, Install carbon monoxide detector(s) within 10 feet of all bedrooms
- Basement, all branch circuit wiring is removed, reinstall to new code. Count 16 circuits on electrical permit.
- All added receptacles must be grounded, tamper-resistant and be on an Arc-Fault Circuit Interrupter-protected circuit.
- Any open walls or walls that are opened as part of this project must be wired to the standards of the current NEC.
- All buildings on the property must meet the St. Paul Property Maintenance Code (Bulletin 80-1).
- All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING

- Basement - Water Heater - T and P relief discharge piping incorrect (MPC 2210 Subp. 4)
- Basement - Water Heater - Water piping incorrect (MPC 1730 Subp. 1)
- Basement - Water Heater - not fired or in service (MPC 2180)
- Basement - Water Meter - meter is removed or not in service (MPC 4715.1700)
- Basement - Water Meter - raise meter to a minimum 12 inches above floor (MPC 2280)
- Basement - Water Meter - support meter properly (MPC 2280)
- Basement - Water Piping - add appropriate hangers (MPC 1430 Subp. 4)
- Basement - Water Piping - boiler fill water line requires backflow assembly or device (MPC 2100)
- Basement - Water Piping - provide water piping to all fixtures and appliances (MPC 1700)
- Basement - Water Piping - repair or replace all corroded, broken or leaking piping (MPC 4715.1720)

- Basement - Water Piping - run 1 inch water line from meter to first major take off (SPRWS Water Code)
- Exterior - Lawn Hydrants - Requires backflow assembly or device (MPC 2000)
- First Floor - Lavatory - fixture is broken or parts missing (MPC 0200 0.)
- First Floor - Lavatory - waste incorrect (MPC 2300)
- First Floor - Lavatory - water piping incorrect (MPC 0200 P.)
- First Floor - Tub and Shower - provide anti-scald valve (MPC 1380. Subp. 5)
- First Floor - Tub and Shower - replace waste and overflow (MPC 1240)
- Second Floor - Lavatory - provide stopper
- Obtain plumbing permits prior to commencement of work.

HEATING

- Clean and Orsat test boiler burner. Check all controls for proper operation. Provide documentation from a licensed contractor that the heating unit is safe.
- Vent clothes dryer to code.
- Provide adequate combustion air and support duct to code.
- Provide support for gas lines to code.
- Plug, cap and/or remove all disconnected gas lines and any unapproved valves.
- Provide a window in the bathrooms with an aggregate glazing area of not less than 3 square feet, one-half of which must be openable or provide exhaust system vented to outside. A mechanical ventilation permit is required if an exhaust system is installed.
- Provide heat in every habitable room and bathrooms.
- Attach metal tag to expansion tank valve stating that this valve must be OPEN at all times except when draining the expansion tank.
- Support supply and return piping for heating system according to code.
- Conduct witnessed pressure test on hot water heating system and check for leaks.
- Install boiler pressure relief valve and pipe discharge to within eighteen inches of the floor.
- Install back flow preventer on city water fill line to hot water heating system and pipe vent as required.
- Repair or replace fin tube radiation and covers as needed.
- Gas and hydronic mechanical permits are required for the above work.

As owner, agent or responsible party, you are hereby notified that if these deficiencies and the resulting nuisance condition is not corrected by **May 30, 2014** the Department of Safety and Inspections, Division of Code Enforcement, will begin a substantial abatement process to demolish and remove the building(s). The costs of this action, including administrative costs and demolition costs will be assessed against the property taxes as a special assessment in accordance with law.

As first remedial action, a Code Compliance Inspection Report must be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989. This inspection will identify specific defects, necessary repairs and legal requirements to correct this nuisance condition. You may also be required to post a five thousand dollar (\$5,000.00) performance bond with the Department of Safety and Inspections before any permits are issued, except for a demolition permit. Call the Department of Safety and Inspections for more information at 651-266-8989.

If this building is located in a historic district or site (noted on page 1, above, just below the property address) then you must contact Heritage Preservation (HPC) staff to discuss your proposal for the repairs required by this order and compliance with preservation guidelines. Copies of the guidelines and design review application and forms are available from the Department of Safety and Inspections web site (see letterhead) and from the HPC staff. No permits will be issued without HPC review and approval. HPC staff also can be reached by calling 651-266-9078.

As an owner or responsible party, you are required by law to provide full and complete disclosure of this "Order to Abate" to all interested parties, all present or subsequent renters and any subsequent owners. The property shall not be sold, transferred or conveyed in any manner until the Nuisance Conditions have been abated and the Certificate of Code Compliance or Certificate of Occupancy has been issued.

The Enforcement Officer is required by law to post a placard on this property which declares it to be a "nuisance condition", subject to demolition and removal by the City. This placard shall not be removed without the written authority of the Department of Safety and Inspections, Division of Code Enforcement. The department is further required to file a copy of this "Order to Abate" with the City Clerk's Office.

If corrective action is not taken within the time specified in this order, the Enforcement Officer will notify the City Council that abatement action is necessary. The City Clerk will then schedule dates for Public Hearings before the City Council at which time testimony will be heard from interested parties. After this hearing the City Council will adopt a resolution stating what action if any, it deems appropriate.

If the resolution calls for abatement action the Council may either order the City to take the abatement action or fix a time within which this nuisance must be abated in accordance with the provisions of Chapter 33 of the Saint Paul Legislative Code and provide that if corrective action is not taken within the specified time, the City shall abate this nuisance. The costs of this action, including administrative costs will be assessed against the property as a special assessment in accordance with law.

If you have any questions or request additional information please contact **Tom Friel** between the hours of 8:00 and 9:30 a.m. at **651-266-1906**, or you may leave a voice mail message.

Sincerely,

Tom Friel
Vacant Buildings Enforcement Inspector

cc: Legistar Approval list and City Council