



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 10, 2010

Josh Casper
325 Cedar Street, Ste. 210
St. Paul, MN 55101

Re: Appeal for property at 974 Cleveland Avenue South
File ID: ALH 10-325

Dear Mr. Casper:

This is to confirm that on November 5, 2010, Marcia Moermond, Legislative Hearing Officer reviewed your appeal in the above-referenced matter and recommended granting a 5.5-inch variance on the openable height of the egress window in the east second floor bedroom and a 4-inch variance on the openable height of the egress window in the west second floor bedroom.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang
Hearing Coordinator

cc: Fire Supervisors

