

RECEIVED

SEP 09 2010

CITY CLERK



APPLICATION FOR APPEAL

Saint Paul City Clerk
15 W. Kellogg Blvd., 310 City Hall
Saint Paul, Minnesota 55102
Telephone: (651) 266-8688

1. Address of Property being Appealed: <u>1133 Melan Ave</u>	2. Number of Dwelling Units: <u>Single Family</u>	3. Date of Letter Appealed: <u>09/02/10</u>
---	--	--

4. Name of Owner: Ben Rausch
 Address: 1133 Melan Ave City: St. Paul State: MN Zip: 55106
 Phone Numbers: Business _____ Residence 651-772-1517 Cellular _____
 Signature: _____

5. Appellant / Applicant (if other than owner): Renewal by Andersen
 Address: 1920 W City Rd C City: Roseville State: MN Zip: 55113
 Phone Numbers: Business 651-264-4088 Residence _____ Cellular _____
 Signature: Bryan Horton

6 State specifically what is being appealed and why (Use an attachment if necessary):
We are appealing 4 replacement gliding windows that do not
comply with Egress Policy Requirements. Windows opening
width will be short by 4" but is compensated by the
9" excess in operable height. Overall glazed area is exceeded
by 5 sq feet. Please Approve

NOTE: A \$25.00 filing fee made payable to the City of Saint Paul must accompany this application as a necessary condition for filing. You must attach a copy of the original orders and any other correspondence relative to this appeal. Any person unsatisfied by the final decision of the City Council may obtain judicial review by timely filing of an action as provided by law in District Court.

For Office Use Only

Date Received:	Fee Received:	Receipt Number:	Date of Hearing: <u>9/21/10 1:30</u>
----------------	---------------	-----------------	---

mailed 9/9/10

Revised 4/25/2007



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: September 2, 2010

APPEAL PROPERTY ADDRESS: 1133 MCLEAN AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-266-9071

PERMIT NUMBER: 10 800354

TYPE OF WINDOW Slider

NUMBER OF WINDOWS 4

Total Glazed Area	10	Difference from Required Area	+5
Width of Opening	16	Difference from Required Opening	-4
Height of Opening	32	Difference from Required Opening	+8
Height of Opening to Finished Floor	30	Difference from Maximum Height	ok

COMMENTS: With the information provided above, approval is recommended. 9-2-10 rr

Reviewed by: Rehn