



APPLICATION FOR APPEAL

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

RECEIVED
~~MAY 14~~ 2012
CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- Copy of the City-issued orders or letter which
are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 6-19-12

Time 1:30 PM

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 11031 Birmingham St. City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Window World Email mollymc@windowworldmn.com

Phone Numbers: Business 651-770-9011 Residence _____ Cell _____

Signature: Molly McFarlane Date: 5/8/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- ~~Other~~ Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other _____
- Other _____
- Other _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 5/8/11

APPEAL PROPERTY ADDRESS: 1631 BIRMINGHAM ST

APPLICANT NAME: WINDOW WORLD

PHONE NUMBER: 651-770-9011

PERMIT NUMBER: 11 302536

TYPE OF WINDOW: Awning

NUMBER OF WINDOWS: One

Total Glazed Area Minimum 5 Square Feet	3.33 sq. ft.	Difference from Required Area	-2.37 sq. ft.
Width of Opening Minimum 20 Inches	40"	Difference from Required Opening	+ 20"
Height of Opening Minimum 24 Inches	12"	Difference from Required Opening	-12"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	58"	Difference from Maximum Height	+10"

COMMENTS:

Reviewed by: David Nelson

Select a Model

(Model 0951)		0951 ▼
Single Vent Awning		
Sash Width	44.0000	
Sash Height	22.1250	
Sash Glass Width	41.0000	
Sash Glass Height	19.1250	
Glass Area (sq.ft.)	5.4453	
Screen Width	41.6250	
Screen Height	19.7500	
Awning Does not Meet Egress		

Min. W: 19	Max W: 48	
Min. H: 16	Max H: 48	Max UI: 96
Exact Size		
Width:	45 5/8	45.625
Height:	23 3/4	23.75
Extrusion:	Select Extrusion ▼	<< For Arch-Top Models Only
Opening:	Exact Size ▼	
Type:	Standard ▼	
Screen:	▼	
Glass:	Double Strength (3 mm) ▼	

AC Sash Calculator