



**CITY OF SAINT PAUL**  
OFFICE OF THE CITY COUNCIL  
310 CITY HALL  
15 WEST KELLOGG BOULEVARD  
SAINT PAUL, MN 55102-1615  
EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)  
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 1, 2010

Allen Hambleton  
A Pane in the Glass Construction  
452 W. Horseshoe  
St. Paul, MN 55126

Re: Appeal for property at 558 Ottawa Avenue.  
File ID: ALH 10-303

Dear Mr. Hambleton:

This is to confirm that on October 28, 2010, Marcia Moermond, Legislative Hearing Officer reviewed your appeal in the above-referenced matter and recommended granting a 2-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 22 inches high by 25.4 inches wide.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang  
Paralegal

cc: Fire Supervisors (email)  
Pat Fish (email)  
Jim Boom (email)  
Ryan Rehn (email)  
Stephen Ubl (email)

