


RECEIVED
SEP 23 2010

CITY CLERK



Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 9/23/10

To FAX#: 6-8574
6-8560

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To: Vicki Sheffer

Location: City Hall

Sender: St. Paul - Ramsey County Dept. of Public Health
Tim Yannarely / Bruce Noyes

This transmission consists of 2 pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1142 (Bruce Noyes)

Message:

Egress Window Non-Compliance Determination
See attached

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.

10/5 1:30



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 9/23/10

APPEAL PROPERTY ADDRESS: 125 ROBE STREET WEST
ST. PAUL RAMSEY COUNTY
APPLICANT NAME: DEPT. OF PUBLIC HEALTH PHONE NUMBER: 651-266-1142
FOR OWNERS ANNA + CRAIG BUTLER / 651-222-1774

PERMIT NUMBER: _____

TYPE OF WINDOW: DOUBLE HUNG

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 8.8 sq ft

DIFFERENCE FROM REQUIRED AREA: Complies

WIDTH OF OPENING: 25.5 inches

DIFFERENCE FROM REQUIRED OPENING: Complies

HEIGHT OF OPENING: 23 inches

DIFFERENCE FROM REQUIRED OPENING: 1 inch

HEIGHT OF OPENING TO FINISHED FLOOR: Less than 48"

DIFFERENCE FROM MAXIMUM HEIGHT: Complies

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____