

Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 5-4-12

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To FAX#: 6-8574

To: Mai Yang Paralegal

Location: Legislative Hearing Office
City of St. Paul

Sender: Daniel Schmidt / Tim Hannareilly
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of 5 pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1173 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination
Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.

RECEIVED
MAY 04 2012
CITY CLERK



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 5-4-12

APPEAL PROPERTY ADDRESS: 751 Cottage Avenue

APPLICANT NAME: Rubie Heath (Daniel Schmidt) PHONE NUMBER: 266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8.4 sqft DIFFERENCE FROM REQUIRED AREA: Comp


WIDTH OF OPENING: 23.2" DIFFERENCE FROM REQUIRED OPENING: Comp

HEIGHT OF OPENING: 20" DIFFERENCE FROM REQUIRED OPENING: 4"

HEIGHT OF OPENING: 248" DIFFERENCE FROM MAXIMUM HEIGHT: Comp

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____



Select a Model

(Model 0201)

Excilbur Double Hung

Model

Top Sash Width	24.3790
Top Sash Height	26.1875
Bottom Sash Width	25.3170
Bottom Sash Height	26.1875
Top Glass Width	22.8875
Top Glass Height	22.6090
Bottom Glass Width	21.8875
Bottom Glass Height	24.3900
Screen Width	21.5375
Screen Height	27.8250
Top Sash Weight (Plus 5 lb)	20 lb
Bottom Sash Weight (Plus 5 lb)	10 lb
Top Balance Size (Steel)	24.75
Bottom Balance Size (Steel)	24.75
Bottom Balance Size (Al)	24.75
Bottom Balance Size (Special)	24.75
Screen Opening Width	23.180
Screen Opening Height	28.0000
Screen Opening Area (sq ft)	3.220

Min. Wt. 11

Max. Wt. 52

Min. Ht. 20

Max. Ht. 63

Max. Lf. 132

Fixed Size

Width: 27.625

Height: 63.5

Exterior Sash Position: Open Closed Tilted Inverted

Opening: Top Bottom Both


Type: Standard Special

Screen: 1/2" 3/4" 1" 1 1/2" 2"

Glass: Double Strength (3 mm) Triple Strength (6 mm)

☐ AC Sash Operator

* 23.9 x 50.6 = 1209 ÷ 144 = 8.4 sq ft



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 5-4-12

APPEAL PROPERTY ADDRESS: 751 Cottage Avenue

APPLICANT NAME: RUSHE HEIGHT (DANIEL SATTNER) PHONE NUMBER: 266-1143

PERMIT NUMBER:

TYPE OF WINDOW: CASEMENT

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 5.6 ft² DIFFERENCE FROM REQUIRED AREA: 0.1 ft²

WIDTH OF OPENING: 17.1" DIFFERENCE FROM REQUIRED OPENING: 2.9"

HEIGHT OF OPENING: 41.1" DIFFERENCE FROM REQUIRED OPENING: COMP

HEIGHT OF OPENING: 448" DIFFERENCE FROM MAXIMUM HEIGHT: COMP

RECOMMENDATION (IF APPLICABLE):

FROM: _____

$$* 40.8 \times 19.9 = 811.92 = 5.6 \text{ sq ft}$$