



# APPLICATION FOR APPEAL

RECEIVED

JAN 23 2012

CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number \_\_\_\_\_)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

YOUR HEARING Date and Time:	
Tuesday, <u>Tuesday,</u>	
<u>2/07/2012</u>	
Time <u>1:30 P.M.</u>	
Location of Hearing:	
<u>Room 330 City Hall/Courthouse</u>	

## Address Being Appealed:

Number & Street: 1686 Idaho Ave E City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Tony Swanson Email anthony.swanson@stpha.org

Phone Numbers: Business 651-298-4907 Residence \_\_\_\_\_ Cell \_\_\_\_\_

Signature: [Handwritten Signature] Date: 1-20-12

Name of Owner (if other than Appellant): Public Housing Agency of St. Paul

Address (if not Appellant's): 555 N. Wabasha Suite # 400 St. Paul, MN 55102

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

#1 Bedroom S Side - MSFC 1026.1  
Request variance on openable height.

C: K. LYKSETT  
B. SHERRY

DEPARTMENT OF SAFETY AND INSPECTIONS  
Fire Inspection Division  
Ricardo X. Cervantes, Director



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

January 12, 2012

BETTY LOU AUTHIER  
PUBLIC HOUSING AGENCY  
200 ARCH ST E  
ST PAUL MN 55130-4347

### FIRE INSPECTION CORRECTION NOTICE

RE: 1686 IDAHO AVE E  
Ref. #111462  
Residential Class: C

Dear Property Representative:

Your building was inspected on January 12, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on February 12, 2012 at 10:00A.M.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

#### DEFICIENCY LIST

*B. SHERRY - w/o #6042499*

1. Bedroom S Side - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.- Double hung windows. Openable height is 22 inches . Openable width is 26inches. Glazed is 46inches in height by 22inches in width. Sill is 27inches.

*B. SHERRY - PROVIDE DOCUMENTATION TO NANCY - REC'D*

2. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.  
*N. SCHMIDT - SENT VIA E-MAIL TO JAMES THOMAS 1-11-12.*
3. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.  
*K. LYKSETT - W/O # 6042500*
4. MSFC 605.4 - Discontinue use of all multi-plug adapters.-Cannot piggy back power taps  
*B. SHERRY - W/O # 6042501*
5. SPLC 34.10 (4), 34.33 (3) - Provide a bathroom floor impervious to water. After securing toilet to floor caulk the base.  
*K. LYKSETT - W/O # 6042502*
6. MN Stat 299F.18 - Immediately remove and discontinue excessive accumulation of combustible materials.-Reduce 75% And remove charcoal lighter fluid  
*B. SHERRY - W/O # 6042501*
7. SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 415.0220 - Repair or replace and maintain the plumbing fixture to an operational condition.-Repair or replace and maintain an approved private toilet. Secure toilet to floor

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [james.thomas@ci.stpaul.mn.us](mailto:james.thomas@ci.stpaul.mn.us) or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas  
Fire Inspector

Reference Number 111462