



# APPLICATION FOR APPEAL

RECEIVED  
AUG 07 2012  
CITY CLERK

Saint Paul City Clerk  
310 City Hall, 15 W. Kellogg Blvd.  
Saint Paul, Minnesota 55102  
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul  
(if cash: receipt number 351832)
- Copy of the City-issued orders or letter which  
are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR  Mail-In

<i>YOUR HEARING Date and Time:</i>
Tuesday, <u>August 14, 2012</u>
Time <u>1:30 p.m.</u>
<i>Location of Hearing:</i>
<u>Room 330 City Hall/Courthouse</u>

## Address Being Appealed:

Number & Street: 410 Van Buren City: St. Paul State: MN Zip: 55104

Appellant/Applicant: Margaret Uriah@gmail.com Email MargaretUriah@gmail.com

Phone Numbers: Business 651-292-3000 Residence \_\_\_\_\_ Cell 612 845 5089

Signature: Margaret Uriah Date: 7/23/12

Name of Owner (if other than Appellant): Du Hast Vier, LLC

Address (if not Appellant's): 501 Dale St. Suite 300 St. Paul mn. 55103

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

## What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

We used class 5 Rock which  
is a dustless surface and  
used it in the same place that  
was at the back half of property  
where original parking area is.



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989  
Saint Paul, MN 55101-1806 Fax: 651-266-8951

July 18, 2012

DU HAST VIER LLC  
8388 -- 137TH CT  
APPLE VALLEY MN 55124-7203

## CORRECTION NOTICE - RE-INSPECTION COMPLAINT

RE: 410 VAN BUREN AVE

Dear Property Representative:

A re-inspection was made on your building on , in response to a referral. You are hereby notified that the following deficiencies must be corrected immediately.

**A re-inspection will be made on or after July 31, 2012.**

Failure to comply may result in a criminal citation or the revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

### DEFICIENCY LIST

1. Exterior - SPLC 34.08 (7) - All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-9090.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

If you have any questions, email me at [lisa.martin@ci.stpaul.mn.us](mailto:lisa.martin@ci.stpaul.mn.us) or call me at 651-266-8988 between 6:30 a.m - 8:30 a.m.

Please help to make Saint Paul a safer city in which to live and work.

Sincerely,

Lisa Martin  
Fire Inspector