

## **Moermond, Marcia (CI-StPaul)**

---

**From:** Moermond, Marcia (CI-StPaul)  
**Sent:** Friday, July 15, 2016 10:38 AM  
**To:** Neis, Adrian (CI-StPaul); Vang, Mai (CI-StPaul)  
**Cc:** Huseby, Laura (CI-StPaul)  
**Subject:** RE: 2250 Luther Place appeal

Thanks AJ. This item is scheduled to show up on our agenda 7/26. At that time we will close the appeal file indicating the orders have been withdrawn. Mai, can you communicate this to the appellant? Thank you.

---

**From:** Neis, Adrian (CI-StPaul)  
**Sent:** Thursday, July 14, 2016 3:08 PM  
**To:** Moermond, Marcia (CI-StPaul); Vang, Mai (CI-StPaul)  
**Cc:** Huseby, Laura (CI-StPaul)  
**Subject:** 2250 Luther Place appeal

I inspected the storage locker at 2250 Luther place. The storage was 18 inches below the sprinklers.

The locker installation would not have required a permit, and does not appear to adversely affect the sprinkler coverage where it would interfere with the operation.

DSI will be withdrawing the order.

Laura, please abate your order. If it is the only remaining violation, you can approve the CofO.

AJ