

□ Other

## **APPLICATION FOR APPEAL**

RECEIVED
JUN 2 1 2011
CITY CLERK

## Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

The City Clerk needs the following to p	rocess your appeal:	
\$25 filing fee payable to the City of (if cash: receipt number)  Copy of the City-issued orders or le are being appealed  Attachments you may wish to inclu This appeal form completed  Walk-In OR □ Mail-In	Saint Paul etter which	YOUR HEARING Date and Time:  Tuesday,
Address Being Appea		St. Phy State: My 55104
Appellant/Applicant:	Walsh E	mail
Signature:		Cell Date:
Name of Owner (if other than Appellant)  Address (if not Appellant's):		
Phone Numbers: Business	Residence	Cell
What Is Being Appeal	ed and Why?	Attachments Are Acceptable
Vacate Order/Condemnation/ Revocation of Fire C of O  Summary/Vehicle Abatement  Fire C of O Deficiency List  Fire C of O: Only Egress Windows  Code Enforcement Correction Notice	water Preasi	NYC
□ Vacant Building Registration		



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806 

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

June 16, 2011

DANIEL J WALSH 510 SARATOGA ST S ST PAUL MN 55116-1546

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES 652 IGLEHART AVE

Ref. # 107274

## Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on June 15, 2011. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. A reinspection will be made on June 30, 2011 at 11 a.m..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

## **DEFICIENCY LIST**

- 1. Basement By Laundry MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.
- 2. Interior-Basement UMC 504.6 Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work requires a permit(s). Call DSI at (651) 266-8989.-This permit has not been finaled. Further corrections and inspection required by warm air inspector.
- 3. Interior SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 415.0220 Repair or replace and maintain the plumbing fixture to an operational condition.-Hire a licensed plumber to repair very low water pressure to the kitchen sinks and repair the fixture in unit 2 that leaks.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at leanna.shaff@ci.stpaul.mn.us or call me at 651-266-8980 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Leanna Shaff Fire Inspector Ref. # 107274