



APPLICATION FOR APPEAL

RECEIVED
DEC 08 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 12-20-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 283 Wyoming ST F City: ST PAUL State: MN Zip: 55107

Appellant/Applicant: HARVSTER INVESTMENTS / Home Sweet Home Construction Email Jmacdonald@usfamily.net

Phone Numbers: Business 612-986-4246 Residence _____ Cell _____

Signature: [Signature] Date: 12/8/11

Name of Owner (if other than Appellant): HARVSTER INVESTMENTS LLC

Address (if not Appellant's): 1845 Stevens Blvd, apt 5 MN 55418

Phone Numbers: Business _____ Residence _____ Cell 612-986-4246

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____
- Other _____
- Other _____
- Other _____



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: December 8, 2011

APPEAL PROPERTY ADDRESS: 283 WYOMING ST E

APPLICANT NAME: HOME SWEET HOME CONSTRUCTION

PHONE NUMBER: 763-535-5448

PERMIT NUMBER: 11 256349

TYPE OF WINDOW Casement

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	7	Difference from Required Area	+2
Width of Opening Minimum 20 Inches	15"	Difference from Required Opening	-5"
Height of Opening Minimum 24 Inches	42"	Difference from Required Opening	+18"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	Ok

COMMENTS: N/A

Reviewed by: J Hoffman 12-8-11