



APPLICATION FOR APPEAL

RECEIVED
JUN 28 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 7-5-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 264 E. Wyoming City: St. Paul State: MN Zip: 55107

Appellant/Applicant: THD At-Home Service, Inc,
2690 Cumberland Pkwy, Ste 300 Mail _____
Atlanta, GA 30339-3913

Phone Numbers: Business _____ Lic # 20268257 Ph. 763/542-8826 Cell 763-213-3611

Signature: [Signature] Date: 6/28/2011

Name of Owner (if other than Appellant): Thomas Lloyd

Address (if not Appellant's): 264 E. Wyoming Street

Phone Numbers: Business _____ Residence 651/290-9984 Cell 612/201-9757

What Is Being appealed and why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 28, 2011

APPEAL PROPERTY ADDRESS: 264 WYOMING ST E

APPLICANT NAME: HOME DEPOT AT HOME SERVICES THE

PHONE NUMBER: 770-779-1300

PERMIT NUMBER: 11 244950

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	6	Difference from Required Area	+1
Width of Opening Minimum 20 Inches	19	Difference from Required Opening	-1
Height of Opening Minimum 24 Inches	20	Difference from Required Opening	-4
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	ok

COMMENTS: NA

Reviewed by: dd 6-28-11



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 28, 2011

APPEAL PROPERTY ADDRESS: 264 WYOMING ST E
APPLICANT NAME: HOME DEPOT AT HOME SERVICES THE
PHONE NUMBER: 770-779-1300
PERMIT NUMBER: 11 244950
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 3

Total Glazed Area Minimum 5 Square Feet	3.33 sq. ft.	Difference from Required Area	-1.67 sq. ft.
Width of Opening Minimum 20 Inches	15.5"	Difference from Required Opening	-4.5"
Height of Opening Minimum 24 Inches	10.5"	Difference from Required Opening	-13.5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	45"	Difference from Maximum Height	+3"

COMMENTS: N/A

Reviewed by: dd 6-28-11